# **ADDENDUM #2**

### TERREBONNE PARISH CONSOLIDATED GOVERNMENT

## HURRICANE IDA-WOMEN'S CORRECTIONAL JUSTICE CENTER - REPAIRS 3181 GRAND CAILLOU ROAD HOUMA, LOUISIANA

**ARCHITECT'S PROJECT NUMBER: T667B-0622** 

**April 25, 2023** 

CHERAMIE+BRUCE ARCHITECTS, PROFESSIONAL CORPORATION P.O. Box 1247 HOUMA, LOUISIANA 70361 PHONE: (985) 868-5020 EMAIL: daniel@cb-arch.com The Contract Documents for the Terrebonne Parish Consolidated Government Hurricane Ida Women's Correctional Justice Center Repairs as prepared by Cheramie+Bruce Architects, Professional Corporation, P. O. Box 1247, Houma, Louisiana, dated March 24, 2023, are hereby modified, corrected and/or supplemented by this Addendum #2, as follows:

### **GENERAL NOTES**

1. Prime Bidders who attended the **Non-Mandatory** Pre-Bid Conference:

Company	LA Lic. No.	Phone	Email
Foret Contracting Group	44882	985-492-3315	bids@foretgroup.com
Group Contractors	31838	225-278-5994	jford@groupcontractors.com
TBT Contracting	67045	985-400-1221	office@tbtcontracting.com
Edward J. Laperouse Metalworks	2240	985-872-4511	brentt@lapmetal.com

2. Others who attended the **Non-Mandatory** Pre-Bid Conference:

Company	Phone	Email
Cheramie+Bruce Architects, PC	985-868-5020	daniel@cb-arch.com
Terrebonne Parish Consolidated Government	985-209-1549	jportier@tpcg.org

- 3. Contractors that have listed themselves as Prime Bidders can be found at <u>Central Bidding Visitors (centralauctionhouse.com)</u>. It is suggested that any contractor bidding as a Prime Bidder list themselves as such on Central Bidding.
- 4. The Contractor shall be responsible for applying and paying for all necessary permits. Contractors should contact the Terrebonne Parish Permit Office (985-873-6567) for further information.
- 5. The current Base Bid Opinion of Cost (OPC) is \$1,513,302.00
- 6. Contractors wishing to visit the project site shall make accommodations with Mr. Junius Portier 1-985-209-1549; <u>iportier@tpcg.org</u>.

#### PROJECT SPECIFICATIONS

- 1) Invitation to Bidders **CHANGE** Bid Date as follows:
  - a) Sealed bids will be received on <u>Thursday</u>, <u>May 25, 2023</u>, by the Terrebonne Parish Consolidated Government (TPCG) Purchasing Division, at the City of Houma Service Complex, 301 Plant Road, in Houma, Louisiana until 2:00 P.M. as shown on the Purchasing Division Conference Room Clock, and TPCG shall at that time and place publicly open the bids and read them aloud.
- 2) Section 01 5000 Temporary Facilities and Controls
  - a) Paragraph 1.02 Temporary Utilities: **ADD** Owner will provide electrical power and water supply consisting of connection to existing facilities. Contractor shall police power and use trigger operated nozzles for water hoses to avoid waste.
- 3) Section 07 5200
  - a) Paragraph 1.05 Description of Work
    - i) Item A, 1: **CHANGE** Project Type shall be Full Tear Off back down to existing metal deck.

- ii) Item A, 3: **CHANGE** Substrate shall be new, tapered polyiso insulation system with 5/8" roof cover board, mechanically attached to existing 22-gauge metal deck.
- iii) OMIT Item A, 4.
- iv) Item A, 5: **CHANGE** application to a torch applied system. Base Ply and Cap Ply shall be torch grade (TG).

END OF ADDENDUM #2