



October 22, 2020

**ADDENDUM NO. 2**

**TERREBONNE PARISH CONSOLIDATED GOVERNMENT**

**LOWER LITTLE CAILLOU DRAINAGE PUMP STATION REPLACEMENT (D-04)**  
**PARISH PROJECT No. 16-DRA-67, STATE PROJECT No. H.011459**  
**DCC Project No. 2016.068**

**TO:** All holders of record of contract documents

**GENERAL:** The following items shall be considered part of the contract documents and shall be included in the same when the construction contract is executed. Changes made by addenda shall take precedence over original documents. Any changes which may affect construction or proper installation of materials or equipment not specifically mentioned in this addendum should be brought to the attention of the Engineer before submitting bid. Otherwise, such conditions, if found later to exist, must be worked out in an acceptable manner without additional cost to the Owner. General contractors are hereby advised to call attention of all subcontractors and/or suppliers to changes which may affect their work and/or product.

Acknowledge receipt of this addendum by inserting its number, date, and signing or initialing in the proper blanks appearing on the Louisiana Uniform Public Work Bid Form. Failure to comply with the above will subject Bidder to disqualification.

**I. GENERAL INFORMATION:**

1. Electronic Bids ONLY will be received on Tuesday, October 27, 2020 at 2:00 PM by the Terrebonne Parish Consolidated Government (TPCG) Purchasing Division, at the City of Houma Service Complex, 301 Plant Road, Houma, LA.

**II. PLAN SHEETS:**

1. Sheet 2, General Notes and Summary of Estimated Quantities, General Notes, add the following note: '36. The TPCG will assist the Contractor will off-loading of salvaged material and equipment from the existing pump station at their South Campus Facility.'
2. Sheet 34, Mechanical Details, Fuel Piping Schematic, replace "3/8" HP Flex Fuel Line" call out with '1/2" HP FLEX FUEL LINE' callout.
3. Sheet 34, Mechanical Details, Fuel Piping Schematic, replace "Oberdorfer Auxiliary Fuel Booster Pump w 3/8" NPT Ports (AFBP) (2 req'd)" call out with 'OBERDORFER AUXILIARY FUEL BOOSTER PUMP W. 1/2" NPT PORTS (AFBP) (2 REQ'D)' callout.
4. Sheet 34, Mechanical Details, Fuel System Piping Legend, replace "Aux. Fuel Booster Pump (AFBP) (Oberdorfer Model N991 Series or Equal)" call out with 'AUX. FUEL BOOSTER PUMP (AFBP) (OBERDORFER MODEL N992 SERIES OR EQUAL)' callout.
5. Sheet 34, Mechanical Details, Notes:, add the following note:  
'5. Solenoid Valves shall be as follows:  
2" Jefferson Z1314 Series or equal  
3/4" Jefferson Z1335 Series or equal'

End of Addendum No. 2