



DEPARTMENT OF FINANCE
Terrebonne Parish Consolidated Government

P.O. Box 2768
Houma, Louisiana 70361-2768

tpcg.org
PHONE 985-868-5050

July 15, 2026

Sent Via: Central Auction House and TPCG Website

RE: Addendum # 1 RFP 26-POLLVE-28 Village East Sewer

To All Proposers,

This letter is considered Addendum #1 for the above reference RFP. Any changes, deletions, and/or additions made by addenda shall take precedence over information in the original document. This addendum is to inform you of the following:

➤ Contractor Questions and Responses:

- On page 2.1 of 2.19 – Scope mentions “setting up a sewer flow control system to manage the operational wastewater services during the pipelining process, of Village East Subdivision sewer system up to, but not including, the sewer lift station located near the intersection of Industrial Park and Development St. in Houma, LA.” Are there any know operational issues with the sewer lift station located near the intersection of Industrial Park and Development St. or any other sewer lift station that affect the sewer flow levels in the Village East Subdivision? *There are no known operational issues with the sewer lift station located near the intersection of Industrial Park and Development Street. The Lafayette Woods, Friendswood, Halette, Industrial C, and Halene lift stations discharge flow through the Village East sewer system to the Coteau Holding Basin.*
- On page 2.5 of 2.19 – Item M. asks us to submit a Conflict of Interest Disclosure. Do you have a standard Conflict of Interest Disclosure form for us to complete and sign or should we compose our own? *A standard Conflict of Interest Disclosure form is provided. Respondents shall include a letter or written statement within the appropriate section of their proposal stating whether they have any conflict of interest. If no conflict exists, the respondent may state that they have no conflict of interest. If a conflict does exist, the respondent shall provide an explanation within the disclosure.*

- The deadline for responding to questions has been moved to 4:00 P.M. 7/15/2026

Should you have any questions or require any additional information do not hesitate to contact me at 985-580-7272.

Sincerely,

Gina Bergeron, Purchasing Division
Terrebonne Parish Consolidated Government