

ADDENDUM NO. 2

FOR

PARISH PROJECT NO. 24-HVAC-11

PHASE II - HVAC RENOVATIONS FOR THE TERREBONNE COURTHOUSE AND COURTHOUSE ANNEX

August 26, 2026

Prepared By:

CASTAGNOS GOODWIN UTLEY ENGINEERS, LLC
200 LA-24
Schriever, Louisiana 70395



Phase II - HVAC Renovations
for the
Terrebonne Courthouse
and
Courthouse Annex
Project No. 24-HVAC-11

Addendum No. 2

The following Clarifications and Revisions made below shall be considered to be within the Scope of work:

Pertaining to Drawings:

Electrical:

1. Refer to sheet E1.1: In lieu of serving new panel "Q" from fusible bus plug (specific note 5), instead serve new panel "Q" from new 480V, 3P,60A circuit breaker in existing panel "N" (ITE) located in Penthouse Mechanical Room. Provide mounting hardware as required. Refer to sheet M1.1 for Penthouse floor plan; panel "N" located plan south of chiller CH2. Route new 1½" c. 4#6, 1#10 GND from Penthouse Mechanical Room down thru chase and continue feeder to panel "Q" above first floor ceiling.